

Municipal Corporation Ludhiana

(Health Branch)

Ref No. : 225/CSI/2BIR

Dated: 19-6-25

TO WHOM IT MAY CONCERN

It is Certified that Water Sample tested from Green Land Convent School, Sec-32 Chandigarh Road, Ludhiana found potable as per laboratory report and the present sanitation condition of school is up to mark.

Amit Singh
Nodal Officer (Health Branch)
Chief Sanitary Inspector
Municipal Corporation, LDR.
Ludhiana

From

The Head
Department of Microbiology
PAU Ludhiana.

To

The Principal
Greenland Convent School
Sector-32, Chandigarh Road
Ludhiana

Memo. No. 2104
Dated: 24/4/25

Subject: Bacteriological quality of drinking water (IS-10500:1991.BIS New Delhi).
Reference is made to your letter no. nil dated 21.04.2025 regarding water sample for bacteriological analysis.

REPORT:

S. No.	Source	Coliform Organisms		Faecal Coliform /E.coli Detected / Not detected
		Present/Absent	Most Probable Number index (<10/100ml)	
01	Water Sample	Absent	-	Not Detected

INFERENCE

Bacteriologically Safe :- 01

*Bacteriologically not Safe :- Nil

Amrinder Singh
Technician
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

[Signature] 24/4/25
Incharge
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

Note: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

[Signature] 24/4/25
Head
Department of Microbiology

*Treatment for non-potable water as per WHO recommendations: Treat 20L of water with 1mL dose of 10% Sodium hypochlorite or 1.8mL dose of 5% Sodium hypochlorite solutions with retention time of 30 mins. The water must be used within 24 hours of treatment. The solution is available with all the chemical stores.

[Signature]
8284908808